



WIRING DIAGRAM

GAS / ELECTRIC / HYDRONIC SYSTEMS



- △1 MODEL R1 RELAY -- SPDT RELAY W/ 24VAC COIL
- △2 CONNECTION FOR FRESH AIR / OUTSIDE AIR DAMPER
- △3 ACTUAL EQUIPMENT WIRING MAY VARY
- △4 FIELD JUMPER -- MUST BE BETWEEN 'AUX R' & LOWER 'CO²' TERMINALS
- △5 'AUX RLY' DIP SWITCH MUST BE SET TO 'DA' - DIRECT ACTING
- △6 DELAY ON MAKE RELAY. SET FOR A MINIMUM OF 60 SECONDS, TO PREVENT THE POSSIBILITY OF RELAY CHATTER.

UZC4 HVAC SYSTEM OUTPUTS



Englishtown, NJ 07726

DRAWING BY:
EDK

DWG NAME: UZC4 -- FRESH AIR ECONOMIZER W/
MODEL EC: ENTHALPY CONTROL

DATE:
06/16/08

SIZE:
A

REV:
D

DWG NO:
090512A0131


SHEET: 1 OF 2

COPYRIGHT © EWC CONTROLS INC.
ALL RIGHTS RESERVED

DISCLAIMER: EWC Controls Inc., Cannot be held liable for the use or misuse of this supplied information. It is the responsibility of the user to determine the suitability of the application. Malfunctions, improper operation, and/or subsequent damage to any related equipment or property damage as a result of using this supplied information is the responsibility of the user. EWC Controls Inc., is not responsible for any misapplications including, but not limited to negligence, defect in product(s), system incompatibility, poor workmanship and/or installation.


WIRING DIAGRAM

HEATPUMP SYSTEMS



- △1 MODEL R1 RELAY -- SPDT RELAY W/ 24VAC COIL
- △2 CONNECTION FOR FRESH AIR / OUTSIDE AIR DAMPER
- △3 ACTUAL EQUIPMENT WIRING MAY VARY
- △4 FIELD JUMPER -- MUST BE BETWEEN 'AUX R' & LOWER 'CO²' TERMINALS
- △5 'AUX RLY' DIP SWITCH MUST BE SET TO 'DA' - DIRECT ACTING
- △6 DELAY ON MAKE RELAY. SET FOR A MINIMUM OF 60 SECONDS, TO PREVENT THE POSSIBILITY OF RELAY CHATTER.

UZC4 HVAC SYSTEM OUTPUTS



CUSTOM APPLICATION CREATED FOR:
KEVIN HUGHES @ AFFORDABLE HEAT AND AIR

EWC[®]

CONTROLS INC.

Englishtown, NJ 07726

DRAWING BY:
EDK

DWG NAME: UZC4 -- FRESH AIR ECONOMIZER W/
MODEL EC: ENTHALPY CONTROL

DATE:
06/16/08

SIZE:
A

REV:
D

DWG NO:
090512A0131

SHEET: 2 OF 2

COPYRIGHT © EWC CONTROLS INC.
ALL RIGHTS RESERVED

DISCLAIMER: EWC Controls Inc., Cannot be held liable for the use or misuse of this supplied information. It is the responsibility of the user to determine the suitability of the application. Malfunctions, improper operation, and/or subsequent damage to any related equipment or property damage as a result of using this supplied information is the responsibility of the user. EWC Controls Inc., is not responsible for any misapplications including, but not limited to negligence, defect in product(s), system incompatibility, poor workmanship and/or installation.